

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012365235
LIMS Reference ID: AB65235
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: Sterling High School
Customer PO: NJ-DOE (23-4401)
EMSL Sales Rep: Justin Monturano
Received: 11/10/2023 13:00
Reported: 11/27/2023 16:04

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: ST-FB									
Lims Reference ID: AB65235-01						Matrix: Drinking Water		Sampled: 11/10/23 09:35:00	
Metals									
Lead	<1.00		1	1.00	ppb	11/10/23 16:09	11/13/23 15:57	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: ST-01									
Lims Reference ID: AB65235-02						Matrix: Drinking Water		Sampled: 11/10/23 09:40:00	
Metals									
Lead	<1.00		1	1.00	ppb	11/10/23 16:09	11/13/23 15:58	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: ST-02									
Lims Reference ID: AB65235-03						Matrix: Drinking Water		Sampled: 11/10/23 09:45:00	
Metals									
Lead	425		10	10.0	ppb	11/14/23 16:08	11/15/23 20:10	JW1	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012365235
LIMS Reference ID: AB65235
EMSL Customer ID: EPIC62

Attention: James Eberts
 Epic Environmental Services, LLC [EPIC62]
 80 Fork Bridge Road
 Pittsgrove, NJ 08318
 (856) 205-1077
 jeberts@epicenviro.com

Project Name: Sterling High School
Customer PO: NJ-DOE (23-4401)
EMSL Sales Rep: Justin Monturano
Received: 11/10/2023 13:00
Reported: 11/27/2023 16:04

Certified Analyses included in this Report

Analyte	CAS #	Certifications
EPA 200.8 in Drinking Water		
Lead	7439-92-1	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2023
NYSDOH	New York State Department of Health	10872	04/01/2024
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2024
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2024
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2024
California ELAP	California Water Boards	1877	06/30/2024
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2024

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012365235
LIMS Reference ID: AB65235
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Sterling High School
Customer PO: NJ-DOE (23-4401)
EMSL Sales Rep: Justin Monturano
Received: 11/10/2023 13:00
Reported: 11/27/2023 16:04

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted."



Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AB65235

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC							
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts							
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road							
City: Pittsgrove		State/Province: NJ		Zip/Postal Code: 08318		City: Pittsgrove					
Phone : 856-205-1077		Fax :		Phone: 856-205-1077		Fax:					
Project Name: Sterling High School				Email Results To: jeberts@epicenviro.com / teberts@epicenviro.com		Purchase Order: NJ-DOE (23-4401)					
U.S. State where Samples Collected: NJ				Number of Samples in Shipment: 3		Date of Shipment: 11/10/2023					
Sample for Compliance? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> If yes, NPDES? <input type="checkbox"/> Other (Specify):											
Samples Collected by: EMSL <input type="checkbox"/> Client <input checked="" type="checkbox"/> check one				Sampled By (Signature): <i>James Eberts</i>		Samples Received Chilled (Y/N)					
Standard Turnaround Time: <input checked="" type="checkbox"/> 2 Weeks				The following TATs are subject to lab approval: <input type="checkbox"/> 1 Week <input type="checkbox"/> 4 Days <input type="checkbox"/> 3 Days <input type="checkbox"/> 2 Days <input type="checkbox"/> 1 Day							
Failure to complete will hinder processing of samples			Matrix		Preservative		List Test(s) Needed				
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8 Total Lead	Field pH	Field pH Test Time	Field Temp. Deg C	Field Temp. Test Time	Comments
1 ST-FB	<input type="checkbox"/>	<input checked="" type="checkbox"/>	11/10/23 0935	W	2	X					Field Blank
2 ST-01	<input type="checkbox"/>	<input checked="" type="checkbox"/>	0940	W	2	X					Field outlet, Home West
3 ST-02	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0945	W	2	X					Bottle Filler by Nurse
End	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		W		X					
	<input type="checkbox"/>	<input checked="" type="checkbox"/>		W		X					
Released By (Signature)			Date & Time			Received By			Date & Time		
<i>James Eberts</i>			11/10/23			<i>Colleen Palladino</i>			11/10/23 1pm		
Please indicate reporting requirements: <input checked="" type="checkbox"/> Results Only <input type="checkbox"/> Results and QC <input type="checkbox"/> Reduced Deliverables <input type="checkbox"/> Disk Deliverable <input type="checkbox"/> Other _____											
Instructions or Comments: Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.											
Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb											

(Lab) Received Temperature: _____ °C